

Design, construction and performance of the UK's first full-scale passive mine water treatment system for base metal mine drainage

*Adam P Jarvis¹, Catherine J Gandy¹, Rachel Harris², John Malley³,
Arabella Moorhouse², and Hugh AB Potter⁴*


¹Newcastle University, ²Coal Authority, ³National Trust, ⁴Environment Agency

(adam.jarvis@newcastle.ac.uk)



Background

- ~ 7% of freshwaters in England & Wales impacted by abandoned metal mine pollution
- Force Crag mine site, in Lake District national park, first site at which large-scale passive treatment system installed (commissioned April 2014)
- Construction possible as willing landowner – National Trust. Owns mine as last working mine in Lake District National Park
- Treatment system an initiative of Coal Authority, Environment Agency, National Trust and Newcastle University, funded by UK Department for Environment Food and Rural Affairs



Force Crag mine site

- 10 km² watershed
- Upland location
- All drainage to Coledale Beck
- Zn main pollutant




- Major point source is 'Level 1' discharge
- Mined for Pb, Zn, Ba
- Extensive mine waste

Monitoring locations

Diffuse as well as point source pollution. Importance of diffuse sources (waste rock) increases with flow

L0 and L1 are adit discharges; L1 by far the greater source of pollution



Level 1 water quality and flow


Variable	Range	Mean	n
Flow (L/s)	8.5 – 24.4	14.8	21
pH	5.6 – 7.7	6.8	25
HCO ₃ ⁻ (mg/L)	8.5 – 26.8	16.7	28
Cl (mg/L)	4.7 – 7.6	5.7	28
SO ₄ (mg/L)	16.0 – 39.5	26.6	28
Ca (mg/L)	5.1 – 14.5	9.5	28
Mg (mg/L)	1.95 – 5.00	3.30	28
Na (mg/L)	2.40 – 3.60	2.95	28
K (mg/L)	0.32 – 0.62	0.46	28
Fe (mg/L)	0.26 – 1.08	0.52	28
Mn (mg/L)	0.29 – 0.76	0.51	28
Al (mg/L)	0.05 – 0.20	0.08	28
Zn (total) (µg/L)	1 730 – 4 660	2 997	28
Zn (filt.) (µg/L)	1 710 – 4 550	2 950	28
Pb (µg/L)	25.0 – 87.9	43.6	28
Cd (µg/L)	5.00 – 20.00	14.24	28

Poorly mineralised discharge and stream; Zn is main pollutant; comparatively dilute waste stream, but typical of many UK metal mine waters

Treatment system design

- Same layout as a SAPS/RAPS i.e. downwards flow through compost into limestone layer overlying under-drainage pipe network
- But functionally different: objective is to immobilise divalent metals (primarily zinc); no requirement to generate alkalinity /elevate pH (limestone is purely for permeability over drainage pipes)
- Referred to as Vertical Flow Pond (VFP)
- Design informed by lab-scale and 2 year pilot-scale trials
- Large-scale Force Crag system still partly experimental, and therefore close flow control and good monitoring infrastructure key element of design

Treatment system design



- Pilot-scale treatment system performance: ~ 70% Zn removal
- Pilot-scale treatment system residence time: ~ 15 hours

<https://www.gov.uk/government/publications/treatment-of-pollution-from-abandoned-metal-mines>

Treatment system layout





Figure courtesy of Coal Authority


Treatment system layout



- Gravity fed system
- Close flow control to ensure consistency of flow
- Open channel flow control system for ease of maintenance

Treatment system layout

Central baffle separates VFP1 and VFP2 water




Geo-grid covers

V-notch weir plate

Discharge to VFP1 or 2


Height-adjustable penstock (1) controls water level in penstock chamber, water level in VFP approach channel (2), and therefore height and flow-rate of water over V-notch to each VFP (3). Excess water overflows penstock (dashed blue arrow), back to Coledale Beck via overflow pipe (4).

Treatment system layout



- Within each VFP have 4 independent perforated pipe drainage networks of equal area

Treatment system layout



Compost:

- 45% BSI PAS 100 compost
- 45% wood chips
- 10% municipal WWTP activated sludge

Treatment system layout


A. Under drainage perforated pipe



B. Limestone (200 mm) and compost (500 mm) being placed over drainage



Treatment system layout



1. Location of Level 1 discharge
2. Subsurface drain diverts groundwater around treatment system
3. One of two flat V weirs for flow measurement in the Coledale Beck
4. Outlet chamber, VFP1
5. Inlet pipe to VFP1
6. Location of flow splitter

Vital statistics


Each VFP:

Surface area (top of compost)	760 m ²
Volume of compost	400 m ³
Volume of limestone	110 m ³
Design flow-rate	3 L/s
Nominal residence time in compost	18.5 hours

- Short residence time particularly important given UK land constraints (actual HRT being checked with tracer tests)
- Combined design flow of 6 L/s (less than total flow of Level 1 discharge due to restriction on land area available)


Treatment principles

- As elsewhere, key process is bacterial sulfate reduction (BSR):




- System design based on a pilot-scale system that operated for 2 years (different site, but very similar water)
- Level 1 mine water is not acidic (mean pH = 6.8), and therefore sole objective to immobilise Zn as sulfide
- Sulfate concentrations in Level 1 water relatively low (16.0 – 39.5 mg/L), and therefore lab tests to ensure sulfate reduction would occur

Treatment system performance: Zn



- Mean Zn removal (03/04/2014 – 18/10/2014) = **96.8%** ($n = 27$)
- VFPs 1 and 2 perform rather differently, despite same size, flow-rate and treatment media


Treatment system performance: Zn



•Filtering effluent samples through 0.45 and 0.10 µm filters shows Zn in effluent is in colloidal form (ZnS?)

Note: 0.10 µm filtered sample concentrations consistently below detection limit of 0.01 mg/L, and therefore reported here as 0.005 mg/L

Treatment system performance: SO₄




- Substantial attenuation of sulfate in treatment system, despite low influent concentration. Strong odours of H₂S.
- Rate of sulfate reduction appears as though it may be influenced by temperature i.e. higher rate during warmer temperatures

Treatment system performance


- Mean Zn removal to date (96.8%) substantially better than predicted from pilot-scale system (68%)
- On average, 3.35 mg/L Zn in Level 1 water, and 18.5 mg/L SO_4 removed during treatment. Equates to $51.5 \text{ mmol/L} \times 10^{-3} \text{ Zn}^{2+}$ and $64.0 \text{ mmol/L} \times 10^{-3} \text{ S}^{2-}$
- According to chemical reactions for the precipitation of ZnS(s) via BSR, 1 mole of Zn will be immobilised as ZnS for every 1 mole of S^{2-} liberated from SO_4^{2-} . Therefore appears as though sufficient BSR to immobilise all of Zn in mine water.
- Appears possible that all Zn is precipitated, but a small proportion physically entrained from treatment system in colloidal form

Treatment system performance



- Initially elevated concentrations of BOD, COD, NH₄-N and PO₄, but decreased rapidly
- Not an issue at this site, but could be at others (e.g. abstractions)

Treatment system performance



- Faecal coliform counts suddenly and dramatically decreased

Conclusions

- First 7 months of operation show very successful performance, although short-term secondary pollution due to organics
- But true success will be long-term attenuation of zinc
- Possible limitations to long-term successful operation an ongoing area of work:
 - Carbon limitation
 - S^{2-} toxicity / inhibition of sulfate reducing bacteria
 - Physical compaction of substrate / short-circuiting
- Management of metal-rich compost at end of life an important issue, and likely a key determinant of full life cycle costs (subject of ongoing PhD study at Newcastle)



Photo by John Malley