

Wastewater Treatment of high total dissolved solids and acidity in Cerro de Pasco mining wastewater

Presented by

Melissa Rhodes

Golder Associates, Inc.



Presentation Outline



Project Overview

Influent Design Basis

Treatment Technology

Bench Testing

Results

Conclusions

Project Overview



Project Overview



Project Goals

- Meet LMP standards
- Expand treatment plant capacity
- Reduce operating costs


Project Overview





Water Quantity



Source	% of Total Flow	
	Current Flow	Expected Future Flow
Underground mine	85.7%	49.8%
Pampa Seca stockpile	1.7%	1.8%
Rumiallana stockpile	5.7%	13.1%
Open pit	1.2%	2.6%
Paragsha industrial zone	5.7%	5.2%
Other stockpiles	0.0%	2.6%
Quiluacocha tailings pond / Excelsior stockpile	0.0%	24.8%



Water Quality



Water Quality



Parameters	Units	Influent Sources						
		Underground Mine	Pampa Seca	Rumiallana	Open Pit	Paragsha	Other Stockpiles	Quilulacocha
General Chemistry								
pH	-	2.28	0.75	2.44	6.26	2.5	2.09	2.4
TSS	mg/L	68	110	18	14	6	97	18
TDS	mg/L	10,000	180,000	17,000	1,300	11,000	170,000	26,000
Acidity	mg/L	4,500	170,000	1,500	190	3,000	4,300	8,500
Sulfate	mg/L	8,300	200,000	13,000	890	9,400	190,000	30,000

Water Quality



Parameters	Units	Influent Sources						
		Underground Mine	Pampa Seca	Rumiallana	Open Pit	Paragsha	Other Stockpiles	Quilulacochoa
Metals (Dissolved)								
Arsenic	mg/L	6	850	0.084	0.093	0.083	220	2.1
Cadmium	mg/L	0.69	12	0.42	0.17	1.3	12	1.6
Chromium	mg/L	0.09	2.4	0.01	0.01	0.014	0.62	0.026
Copper	mg/L	87	1,200	0.28	0.16	23	2,500	19
Iron	mg/L	1,200	41,000	250	4.7	660	55,000	2,900
Lead	mg/L	0.042	6	0.63	0.015	0.25	0.97	0.27
Manganese	mg/L	140	1,300	520	45	600	3,500	930
Mercury	mg/L	0.002	0.002	0.002	0.002	0.002	0.002	0.002
Nickel	mg/L	0.22	1.4	0.18	0.04	0.32	4.3	0.28
Zinc	mg/L	400	3,700	420	44	530	7,200	810

Water Quality



Parameter		Unit	Influent Water	LMP Standards	ECA Standards
General Chemistry	Sulfate	mg/L	27,000	-	500
	TSS	mg/L	120	50	
	Conductivity	μS/cm	-	-	-
	pH	-	1.92	6.0 - 9.0	-
Dissolved	Arsenic	mg/L	30	0.1	-
	Copper	mg/L	130	0.5	-
	Iron	mg/L	3,300	2	-
	Manganese	mg/L	420	-	0.2
	Lead	mg/L	0.3	0.2	-
	Zinc	mg/L	730	1.5	-
	Nickel	mg/L	0.52	-	-
	Aluminum	mg/L	230	-	-

Treatment Technology




- Lime precipitation (High Density Sludge)
- Limestone/Lime Two-stage neutralization
- Metals recovery pre-treatment (sulfide precipitation)

Treatment Technology



Lime Precipitation (High Density Sludge)


- Relies on insolubility of heavy metals in the presence of elevated hydroxide ions
- Minimum solubility pH varies by metal ion
- Widely implemented and established solution for ARD waters dominated by Fe chemistry



(Metal hydroxide precipitation)

Treatment Technology


Lime High Density Sludge (HDS)



Treatment Technology

Limestone/Lime Two-Stage Neutralization

- Advantages
 - Lower material costs
 - Can create denser sludge
- Disadvantages
 - Longer reaction times
 - Low utilization due to sulfate armoring
 - Inability to raise pH above 6.0



(Limestone dissolution)

Treatment Technology



Metals Recovery Pre-treatment

- Advantages
 - Creates saleable product
- Disadvantages
 - Additional equipment


Bench Testing



Primary Objectives

- Lime demand
- HDS performance
- Limestone performance
- Metal recovery performance

Bench Testing



Bench Testing Results



HDS Performance

Parameters	Units	Treatment Goals	Raw Water	HDS Recycle	Oxidation
			Total Blend	Decant #10	with Solids Seeding
pH	-	-	1.92	8.4	9.9
Lime Dose (as Ca(OH) ₂)	g/L			10	11.2
Sulfate	mg/L	500	27,000	3,100	1,400
Metals (Dissolved)					
Aluminum	mg/L	-	230	0.1	0.1
Arsenic	mg/L	0.1	30	0.015	0.015
Cadmium	mg/L	0.05	1.9	0.005	0.005
Copper	mg/L	0.5	130	0.015	0.015
Iron	mg/L	2	3,300	0.1	0.1
Lead	mg/L	0.2	0.28	0.009	0.009
Manganese	mg/L	0.2	420	7.4	0.013
Nickel	mg/L	0.5 ¹	0.52	0.04	0.04
Zinc	mg/L	1.5	730	0.072	0.02

Bench Testing Results



Limestone/Lime Performance

Parameters	Units	Treatment Goals	Raw Water	LS + Lime Titration					
			Total Blend	R-1	R-2	R-3	R-4	R-5	R-6
pH	-		1.92	6.23	6.85	8.2	8.76	8.96	9.48
Limestone Dose (as CaCO ₃)	g/L			10	10	10	10	10	10
Lime Dose (as Ca(OH) ₂)	g/L			1	2	3	4	5	6
Sulfate	mg/L	500	27,000	4,700	3,800	3,300	2,600	2,000	1,700
Metals (Dissolved)									
Arsenic	mg/L	0.1	30	0.019	0.02	0.015	0.015	0.015	0.015
Cadmium	mg/L	0.05	1.9	0.42	0.085	0.005	0.005	0.005	0.005
Copper	mg/L	0.5	130	0.018	0.015	0.015	0.015	0.015	0.015
Iron	mg/L	2	3,300	260	40	0.15	0.14	0.1	0.1
Lead	mg/L	0.2	0.28	0.046	0.024	0.009	0.009	0.009	0.009
Nickel	mg/L	0.5 ¹	0.52	0.15	0.04	0.04	0.04	0.04	0.04
Zinc	mg/L	1.5	730	150	17	0.12	0.045	0.027	0.021


Bench Testing Results



Metals Recovery Performance

Parameters	Units	Treatment Goals	Raw Water	Testing			
			Metal Recovery Blend	M-1	M-3	M-4	M-6
pH	-		1.54	4.66	4.98	5.35	5.76
Lime Dose (as Ca(OH) ₂)	g/L		N/A	75	80	82	88
Sulfate	mg/L	500	194,111	N/A	43,000	40,000	31,000
Metals (Dissolved)							
Arsenic	mg/L	0.1	479	0.43	0.28	0.12	0.094
Cadmium	mg/L	0.05	12	11	11	9.2	6.5
Copper	mg/L	0.5	1,966	12	0.78	0.38	0.15
Iron	mg/L	2	49,244	12,000	5,800	3,300	3,000
Lead	mg/L	0.2	3.04	0.55	0.55	0.49	0.41
Nickel	mg/L	0.5 ¹	3.11	4	4	4	4
Zinc	mg/L	1.5	5,761	2,000	670	240	120

Bench Test Results



Bench Testing Results



Conclusions



Project Goals

- Meet LMP standards
 - HDS and Limestone/Lime both meet LMP standards
 - HDS can meet ECA standard for Mn
 - Sulfate minimized to near solubility at end of pipe
- Expand treatment plant capacity
- Reduce operating costs
 - HDS: 10-20% reduction
 - Limestone/Lime: 35% reduction

Thank You!



Co-authors:

- Tom Rutkowski
- Jessa Smith
- Kevin Conroy
- Michael Bratty
- Miguel Cortes

